



REQUEST FOR BIDS

**Transfer Station Retaining Wall Repair Project**  
**RFB 19BCP04A**

May 14, 2019

**ADDENDUM #1**

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Transfer Station Retaining Wall Repair Project. Where provisions of this addendum differ from those of the original Request for Qualifications, this addendum will govern.

ACKNOWLEDGED

\_\_\_\_\_  
Printed Name of Respondent

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED STATEMENT OF QUALIFICATION. FAILURE TO DO SO MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

## ITEMS FOR ADDENDUM #1:

Bastrop County will allow contractors to submit an alternate bid for this project using pricing for either cast-in-place concrete or pre-cast concrete to build the desired retaining wall as specified by the bid document (RFB 19BCP04A). The alternate bid should utilize #6 rebar spaced at one foot both ways and tied to the footer. Contractor will be responsible for supplying a concrete design showing all details of the alternate bid.

Due to the potential change in the scope of work to be bid, Bastrop County is extending the bid closing date. The new closing date and time for RFB 19BCP04A is **2:00PM on Tuesday, June 4, 2019.**

**Q:** Is a bid bond required to bid this project?

**A:** There is NO bid bond required for this project. Please see section K on page 17 of the bid document for bond requirements.

**Q:** Is there an estimate for this project?

**A:** Bastrop County does not have an estimate for this project.

**Q:** Are we able to visit the project site?

**A:** Contractors are able to visit the transfer station Monday through Saturday, 8:00AM through 4:00PM.

**Q:** Are there better plans that explain what is wanted to price in the bid? Can we speak to someone whom knows what the County wants built and can explain it?

**A:** Any clarifying questions that a contractor has must be submitted in an email and will be answered in the form of an addendum to the bid document.