



REQUEST FOR BIDS

Tahitian Village Ingress/Egress Road Project

RFB 19BCP05K

May 21, 2019

ADDENDUM #1

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Tahitian Village Ingress/Egress Road Project. Where provisions of this addendum differ from those of the original Request for Qualifications, this addendum will govern.

ACKNOWLEDGED

Printed Name of Respondent

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED STATEMENT OF QUALIFICATION. FAILURE TO DO SO MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

ITEMS FOR ADDENDUM #1:

- Q) Can we do cast in place boxes? There will be a substantial cost savings for cast in place.
A) Please bid the culverts as precast. Alternate construction methods can be negotiated upon bid award if there is a cost savings.
- Q) Is there a need for a drive way summary?
A) No driveway summary needed as all existing driveways are adjacent to areas of plane & texturize work. Therefore, there will be no significant change in grade or elevation and no driveway summary is needed.
- Q) In the demolition plan, at the intersection of Oak shadow and McAlister, does the first driveway get saw cut?
A) No. Driveway is adjacent to plane & texturize work (no concrete).
- Q) Can we get the CAD file for bidding purposes?
A) Please use the following link to download the CAD files for this project:
<https://www.dropbox.com/sh/45pjuql2zloIf4o/AABwfdqAonMVx1jww2Bv5kOca?dl=0>
- Q) Can the contractor use crushed concrete instead of flex base?
A) Please bid base as **Flex Base**. Substitute treatment can be negotiated upon bid award if it meets the requirements of the county.
- Q) Will Bastrop County or the Engineer be providing survey stakes in stations on this project?
A) No. The contractor is responsible for construction staking. The contact information for the surveyor that provided the topographic survey is: Tetra, (713) 462-6100, Survey@TSATX.com
- Q) Is the Bastrop Restoration Mix not applicable for this project? Is it a replacement for the TxDOT Mix?
A) Please bid the seed per the TxDOT spec per the plans, bid form and specifications.
- Q) What is the estimated value for this project?
A) Bastrop County does not provide Engineer's estimate for projects.
- Q) Will there be a pre-bid meeting for this project?
A) There will not be a pre-bid meeting.
- Q) Can we burn on site?
A) Yes, Contractors can burn on the project site after the debris piles have been cleared by biological monitors. All burning **SHALL** be completed within the silt fenced project area. All debris piles must also have a silt fence in place around the burn area.
- Q) I wanted to see if you had an electronic bid form for this project?
A) Yes, the electronic bid form is available at the Bastrop County website:
<https://www.co.bastrop.tx.us/page/pur.bids>