



REQUEST FOR BIDS

Hall Road Drainage Improvement Project - DR-4232-0072

RFB 25BCP08A

September 17, 2025

ADDENDUM #1

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Hall Road Drainage Improvement Project - DR-4232-0072. Where provisions of this addendum differ from those of the original Request for Bids, this addendum will govern.

ACKNOWLEDGED

Printed Name of Respondent

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED BID. FAILURE TO DO SO, MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.


ITEMS FOR ADDENDUM #1:

Q: The bid sheet calls out two 8' x 6' feet culvert extensions for a total of 16 linear feet, where do these extensions go in the plans?

A: The extensions are poured in place concrete used to square up the skewed pre-cast concrete box culverts with the existing roadway. See attached drawing for reference.

Q: We notice that box culvert is cast in place. We think that the project would be faster and easier if it would be precast box culverts. The road would be more available for longer time if we don't have to wait for it to cure in multiple sets. Can we use precast box culverts?

A: Bastrop County will allow contractors to submit a bid alternate for Precast Box Culverts. Box ends and headwalls will be cast in place concrete. Additionally, Bastrop County will build a bypass for residents prior to the start of construction. The length of time for the road closure is not a large concern.



LAYOUT - 2-8' SPAN x 6' HGT. BOX CULVERT

1. Bastrop County will provide Flow-Line elevation benchmark.
2. Bastrop County will locate Upstream Centerline of Boxes.

BID SHEET - RFB 25BCP08B

COST TO COMPLETE ALL TASKS LISTED IN RFB 25BCP08B	\$	Lump Sum
COST OF BONDS (PAYMENT AND PERFORMANCE)	\$	Lump Sum
ESTIMATED NUMBER OF DAYS TO COMPLETE PROJECT	#	Days
TOTAL PROJECT COST (LABOR, MATERIALS, BONDS)	\$	Lump Sum
COST TO COMPLETE ALL TASKS LISTED IN RFB 25BCP08B USING BID ALTERNATE FOR PRECAST BOX CULVERTS	\$	Lump Sum
AVAILABLE START DATE: _____ (Day) _____ (Month), 2025		

Authorized Signatory:

Date: