



REQUEST FOR BIDS

Bastrop County Precinct 2 Road and Bridge Facility Construction

RFB 25BCP04J

May 29, 2025

ADDENDUM #3

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Bastrop County Precinct 2 Road and Bridge Facility Construction. Where provisions of this addendum differ from those of the original Request for Bids, this addendum will govern.

ACKNOWLEDGED

Printed Name of Respondent

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED BID. FAILURE TO DO SO, MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

ITEMS FOR ADDENDUM #3:

Q: Reached out to my supplier about the Flamepro plywood and online at Menards, it does not appear to come with an ACX sanded finish as requested. Please clarify?

A: Bastrop County was able to locate the ACX fire retardant material from a vendor in Waco (Cowtown Materials, Inc), and therefore Bastrop County will keep the specification as is. Vendor can submit the product listed or an equivalent. Attached is a quote that Bastrop County received for the requested material from Cowtown Materials, Inc. Contractor can use the attached quote for reference and shall verify cost and availability. The attached quote does not guarantee price or availability for the contractor.

Q: On Drawing A604 Wall Type A1 and A2, it says 1 layer of 5/8 Plywood Gypsum, does this mean 1 layer of Gypsum over 1 layer of plywood, or is it supposed to be 1 layer of just Gypsum?

A: Partition Types A1 & A2, 1 layer of 5/8" Plywood ea. side (no gypsum board on these wall types).

COWTOWN MATERIALS, INC.



A GMS COMPANY

QUOTE

ACKNOWLEDGEMENT

**QUOTE ONLY****"A Complete Drywall and Acoustical Supply Center"**

401 Garden Acres Dr, Fort Worth, TX 76140

Tel: (817) 551-1805 | Fax: (817) 568-1301

Amarillo, TX	(806) 379-7866	Midland, TX	(432) 683-6346
Carrollton, TX	(972) 798-8966	Shreveport, LA	(318) 459-2943
Dallas, TX	(214) 330-0423	Texarkana, TX	(903) 791-0036
Fort Worth, TX (North)	(817) 656-1770	Tyler, TX	(903) 593-3966
Frisco, TX	(972) 335-3100	Waco, TX	(254) 870-5757
Lubbock, TX	(806) 743-5100	Wichita Falls, TX	(940) 257-2809

Customer No.	Date	Order No [QU]
4197	05/16/25	105771-00
Entered By		Sales Rep
MNE		BBC1

Order Date	Customer PO Number	Customer Job No	Promise Date	Shipped	Page No.
05/16/25		PREPAID- WACO	05/16/25		1 of 1

Ship Via	Ordered by	Special Instructions
CUSTOMER PICKUP		

SOLD TO

PREPAID- WACO
WACO, TX 76710-9999

SHIP TO

PREPAID- WACO
WACO, TX 76710

Product	Ord	Unit	Description	U/M	Ext	U/P	Amount
FTPLY58X8AC	80	PCS	5/8" 4' X 8' FIRE RATED SHEETING APA AC SANDED TOTAL= BOARD 0.00 , METAL 0.00 , INSUL 0.00 , TILE 0.00 , GRID 0.00	MSF	2560	2,054.50	5,259.52

Tax Details	Received By	Checked By	Totals	
Taxable: Yes - TEXAS			SUBTOTAL	5,259.52
WACO	X	X	TAX	433.91
MCLENNAN	Delivered By		ADD'L CHARGES	0.00
	Waco, TX		TOTAL	5,693.43

CUSTOMER ASSUMES ALL RESPONSIBILITY FOR ANY DAMAGES CAUSED BY TRUCK DELIVERING BEYOND STREET PAVEMENT. ALL TRANSACTIONS REFERENCED HEREIN ARE GOVERNED BY THE TERMS AND CONDITIONS LOCATED AT <https://www.gms.com/terms-conditions>