



REQUEST FOR BIDS

Tahitian Village Unit 3 Drainage Improvement Project

RFB 21BCP09D

September 29, 2021

ADDENDUM #1

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Tahitian Village Unit 3 Drainage Improvement Project Where provisions of this addendum differ from those of the original Request for Bids, this addendum will govern.

ACKNOWLEDGED

Printed Name of Respondent

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED STATEMENT OF QUALIFICATION. FAILURE TO DO SO MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

ITEMS FOR ADDENDUM #1:

Q: CMP 42" please give a specification on corrugation thickness and coatings?

A: TxDOT Item 460 provides specification information for Corrugated Metal Pipes. CMPs shall be asphalt coated.